

User Manual

(Translation of the original instructions)



Electronic Vibration Monitoring Unit

ESW[®]-HOL600/Ex Compact_II (hol600/Ex)

date: 03.07.2024

technical modification possible

holthausen elektronik GmbH is certified according to DIN EN ISO 9001:2015.



Table of Contents

1. Generally basical safety-indications	page 4
2. Packing and the transport	page 4
3. Application.....	page 5
4. Measurement principle	page 5
5. Requirement for operation in Ex-Zone	page 6
6. Grounding concept.....	page 7
7. Mounting of the vibration control unit	page 8
8. Opening and closing of the vibration control unit..	page 9
9. Maintenance.....	page 9
10. Display- and operation- elements.....	page 10
11. Measurement range switching	page 11
12. Analog output	page 11
13. Analog output settings.....	page 12
14. Adjustment of the limiting values.....	page 12
15. Example to adjust the limit value.....	page 13
16. Self test	page 14
17. Housing size.....	page 15
18. Cable connection draft	page 16
19. Type registration	page 17
Declaration of Conformity	appendix

Important information

These operation instructions are to be read through completely and carefully heeded before starting the device. Failure to heed or adhere can result in claims on manufacturer's liability becoming null and void for damages ensuing there from.

Manual action of any manner on the device – with the exception of proper procedures and those described in these operation instructions – lead to forfeit of guarantee and exclusion from liability.

The device is solely intended for the usage as described below. It is particularly not intended for the direct or indirect protection of persons.

holthausen elektronik GmbH assumes no liability whatsoever as regards suitability for some specific purpose.

If any question should remain open, please never hesitate to contact us.

The customer must ensure the traceability of the ESW® device by means of the serial number.

holthausen elektronik GmbH
Wevelinghoven 38, 41334 Nettetal
Phone: +49 (0) 21 53 - 40 08
Fax: +49 (0) 21 53 - 8 99 94
Mail: info@holthausen-elektronik.de

1. Generally basical safety-indications

Don't use this device as the only invigilator, if a malfunctioning of ESW[®]-HOL600/Ex Compact_II could lead to damages on goods or Persons.

To obtain the desired result be sure, that the device with its technical data fits to the bulk of the object you want to supervise.

The sensor is sensitive to shock. A downfall out lower height to a hard substratum can destroy the sensor.

The assembling place and the execution of the assembling of the sensor determine decisively the quality of the sensor signal. The assembling may only happen through qualified and instructed persons.

The electrical hook up is to be done by instructed persons. A mistake by the connection can entail to faulty functions, outfall or ruination of the sensor and electronics.

The ESW[®] should not be used on machines with a very energetic high-frequency structure-borne sound. Through resonance apparitions in the sensor, the device can indicate a much too great or too small value.

Powerful noise sources for instance inverters, in direct closeness of the sensor, electronics or cabling, can result in faulty behaving of the apparatus.

Potential differences and balance currents in the mass guidance can result in faulty behaving too.

The connection cable is resistant against many but not every type of chemicals. Through a damaged cable chemicals could get inside the unit and destroy the electronic. Then the unit would loose their function. Therefore the conditions from the mounting surrounding must be checked. Then the cover material from the cable have to be proofed if it resists these requirements. You can get an overview from the chemical resistance of the cover material from us.

2. Packing and the transport

Note:

- The sensor is sensitive to shock. A downfall out lower height to an hard substratum can destroy the sensor.
- Avoid to kink or tie a knot in the cable.
- Keep the electronic in a dry place.
- In case of a downfall or heckling or squeezing, could the casing or the operation elements or the board get defects.

With adequate warning-labels and through a qualified packaging and storage, you can protect the sensor and electronics at carriage against influences from outside.

3. Application

The ESW[®]-HOL600/Ex Compact_II is used to protect machines, mechanical equipment and, last but not least, the operating personnel from the consequences of impermissibly high vibration stress. It constantly monitors the strength of the vibration and reliably warns when the limit values that can be set in the device are exceeded. In addition, the current value of the vibration magnitude can be measured at any time via the analog output.

4. Measurement principle

The sensor operates according to the piezoelectric principle and converts the mechanical vibrations into an electrical alternating voltage. The subsequent electronics convert the AC voltage signal into a DC voltage that corresponds to the measured vibration velocity. The sensitivity, i.e. the measuring range, can be easily selected in the device by means of switches.

The measured value is compared with two adjustable limiting values G1 and G2, which could be adjusted in range of 10% to 100% with two potentiometers inside the unit. At the analog output the limit values of G1 and G2 can be adjusted when setting of the DIP-switches corresponds to the prove position. If the measured values exceed G2 the critical limit, alarm relay K2 will be activated after e.g. 5 seconds delay time. If limit value G1 is exceeded for more than e.g. 10 seconds, alarm relay K1 will be activated. If the measured value falls below the limit value, the alarm will be cancelled *).

The measured value also controls a constant current source. At the “analog output” the measurement value is proportional to the fitted measurement range available, by voting 0 to 20mA or 4 to 20mA.

The unit includes a self-test feature which allow to test all electronic components inside the unit. After consultation with manufacturer, it is also possible to check the transmission behavior of the entire measuring electronics by means of an externally supplied test signal.

*) Additional supply with alarm memory. After the activation of the alarm relay K1 (or on customer request K2) the unit will remain in the alarm status until an external and manually reset will be activated. This feature is used in such cases, where the vibration control unit is mounted on unreviewable and difficult accessible places. Through this advanced memory function every alarm is registered. Because of variable mounting of one or more parallel connected reset buttons, it is possible to reset the alarm memory from any place or location.

The reset occurs by connection of the external reset contact (violet core) to +24V.

Attention: Pay attention on requirement by entrance in Ex-Zone

5. Requirement for use of units in Ex-Zone 1 and Zone 21

The ESW[®]-HOL600/ExCompact_II/Ex...is a piece of equipment for use in potentially explosive atmospheres according to directive 2014/34/EU in categories 2G (zone 1) for gases and 2D (zone 21) for dusts. The exact area of use can be found on the marking of the device.

Special conditions for safe use or instructions for use of the devices

The dimensions of the flameproof columns are in parts different from the relevant minimum or maximum values of IEC 60079-1:2007. For information on the dimensions at the flameproof columns, please contact the manufacturer.

The housing of the measuring device must be connected via the fastening or the connecting terminal into the potential equalization of the machine to be monitored. The installer must ensure that the equipotential bonding is established by a qualified specialist in accordance with the relevant VDE regulations.

Wire insertion and connection cable

The free line end of the vibration monitor unit must be connected in an enclosure corresponding to one of the ignition protection types specified according to 1 of EN60079-0:2012 or outside the hazardous area.

The open end of the supply line must be connected in accordance with the applicable installation regulations.

For applications in zone 21, the connection cable must be installed to ensure that electrostatic charging cannot lead to ignitable discharges. Cable entry and connection cable are supplied with the device and are approved for the above-mentioned area of use for a minimum temperature resistance of -40°C to +90°C and meet the requirements of the applicable installation regulations.

Connection cable

Attention: The device must never be transported hanging on the connection cable. It is not permissible to change the connection on the device or to replace the cable.

Since the cable entry does not have its own strain relief, the connection cable must be fastened by the user near the cable entry in a radius of approx. 20cm. The fastening must be done in such a way that the cable is not bend and damaged.


In general it is to be noted

The operator/installer must inform himself about the explosion protection regulations applicable to his area of application and comply with them.

The temperature specifications refer to values without backfilling. In case of filling conditions, the installation conditions must be observed.

The supply voltage must be energy-limited and designed in accordance with the applicable Ex regulations.

6. Grounding concept



If an isolated installation is not specially requested, usually through the attachment with screws each case is connected to the local machine ground.

In the ESW[®]-HOL600/Ex Compact_II, the shield is connected to case potential at factory. The internal supply and the signal ground can remain separated from the shield or be connected to the case potential via coupling capacitors, depending on customer requirements.

At the Standard version of the ESW[®]-HOL600/Ex Compact_II, the supply lines are connected to the case potential via capacitors.

Inside the optional plug box, the cable shielding, the box ground and the signal ground could be connected by choice and dependent on local circumstances and requirements.

In big facilities with considerable energy consumption and distances between the machines could such big potential difference be build up, that substantial balancing current on the ground network will occur. Dependent on intensity of such currents is arising of interference's or damaging of the unit the result!

Even at small spatial distances, potential steps really can arise due to ambiguously defined transition points (paint) or moving parts (springs, moving suspensions).


High-energy, high frequency interference, e.g. from inverters, can be inductively or capacitively coupled into the measuring line and does not necessarily obey Ohm's law. For example parallel elements can act as coupling capacitors and wound ground lines as blocking chokes.

Memorize: Ground is not equal everywhere!

→ Check the situation → Plan the grounding concept → Select the facility / realization

7. Mounting of the vibration control unit

- Whole mounting-, connecting- and adjustment-work should be done from qualified personal only!
- Protect the ESW[®]-HOL600/Ex Compact_II definitely against drop, stroke and other mechanical shock!
- The case of the unit must be connected over the attachment or the ground-on-earth-Terminal with the potential compensation of the monitored machine. The connection must be extremely low resistive as well as for long time stable. Doing this, take urgent notice to the related VDE-regulations.



- ① mounting surface
- ② max. screw depth
- ③ secure grub screw M10x25 with loctite

The ESW[®]-HOL600/Ex Compact_II will be mounted via one threaded pin AM10*25 per DIN 913 on the machine to be monitored.

Important

1. Measuring axis has to be coinciding with vibration excitation axis (see case drawing page 15).
2. Take note of the label with instruction notes.
3. The surface has to be plain, clean and free of paint and rust.
4. The tap hole has to be perpendicular to the surface and free of metal-cuttings or other foreign material. Further more the tap hole and the screw have to be free of paint, rust, grease or other isolating components.
5. The grub screw has to be locked with liquid thread protection against unintended loosening.
6. The unit has to be fixed, tight on the surface.
7. The advises to „connection cable“ (page 6), as well as „Opening and closing of the vibration control unit “ (page 9) are absolutely to note.

8. Opening and closing of the vibration control unit

The user must switch off the power supply, before opening the measurement unit. To open the unit the user needs a 1,5mm type of wrench "inbus - key" and a forehead key with two-bore nut, with size of 4mm. The case cover is ensured with a M3 grub screw. These must be loosened before opening of the case cover, with an "inbus - key".

After adjustment of the unit, please control the position of the DIP-switches.

Before closing the unit the O-Ring must be examine. You have to insert a new O-Ring (62 x 2mm, Viton – original spare part) if the old one is brittle, deformed, damaged or already a few month in use.

Please pay attention that the thread and the interior room is oil- and dirt- free. Cleaning around and inside the unit should be done only with clean and dry cloth. The closing and the sealing of the unit is done after approx. seven pitches of cover-nut thread, and ensured via the M3 grub screw.

"Loosen of the grub screw on the case bottom and opening of the bottom nut is not permitted."

Advices for dismantling

Before dismantling the measurement unit, the power supply must be switched off. The connection cable has to be loosened from the supporting surface to avoid damaging of the cable. The vibration control unit should be set free via a 22mm open-end wrench key.

9. Maintenance

The ESW®-HOL600/Ex Compact_II is maintenance free.

The fuse F1 is soldered fixed and should exclusively be replaced by qualified personal. For replacement is a SMD-fuse, type OMF (63V,1A) required.

Tools for case cover opening: 1.5mm type of wrench (Inbus-key)
Adjustable forehead key for two bore nut size 4mm

Factory: H. Sartorius Nachf. GmbH & Co

phone +49 (0) 21 02 / 44 00 - 0

fax +49 (0) 21 02 / 44 00 - 24

10. Operating and setting instructions

The display and operating elements will be accessible after unscrewing the cover of the ESW[®]-HOL600/Ex Compact_II.

Display elements

Operation


LD2	LED green	operation-voltage on
	LED yellow	Self-test "active"

Limit 1, e.g. pre contact

LD1	LED off	measured value < limit
	LED yellow	measured value > limit reponse delay running
	LED orange	relay K1 has switched measured value > limit
	LED red	relay K1 has switched measured value < limit drop-out delay time running

Limit 2, e.g. main contact

LD3	LED off	measured value < limit
	LED yellow	measured value > limit reponse delay running
	LED orange	relay K1 has switched measured value > limit
	LED red	relay K1 has switched measured value < limit drop-out delay time running




Operating elements

P1	Potentiometer for setting limiting value G1	10 to 100%
P2	Potentiometer for setting limiting value G2	10 to 100%
S1	Range 0 to 10mm/s	ON/OFF
S2	Range 0 to 20mm/s	ON/OFF
S3	Range 0 to 50mm/s	ON/OFF
S4	Analog output 0 to 20mA 4 to 20mA	ON OFF
S5	Analog output corresponds to measured value	ON/OFF
S6	Analog output corresponds to limiting value G1	ON/OFF
S7	Analog output corresponds to limiting value G2	ON/OFF
S8	Self test activated	ON/OFF

Setting instructions

After applying the voltage supply the LED LD2 must light up green. The LED's LD1 and LD3 should remain dark. The relays are switching in their normal position.



11. Measurement range switching

The unit has three measurement ranges, which can be selected by the switches S1, S2 and S3. For a proper operation of the unit, only one switch has to be in position "ON", the both other switches should remain in position "OFF".

Range	Switch Position		
	S1	S2	S3
10mm/s	ON	OFF	OFF
20mm/s	OFF	ON	OFF
50mm/s	OFF	OFF	ON

12. Analog output

As the output value will be submitted constant current, by voting 0 to 20mA or 4 to 20mA. The selection occurs by switching over of switch S4. An output current of 20mA meets the 100%-value of the selected measurement range. In the setting of 0 to 20mA is the valid relation 0.2mA per %, in the setting of 4 to 20mA is the valid relation 4mA + (0.16mA per %).

Output range	Switch position
	S4
0 to 20mA	ON
4 to 20mA	OFF

13. Analog output settings


The 0 to 20mA output can be used for displaying of several values on the analog output. With the standard setting the output current corresponds to the measured signal.

For example, an analog current value of 20mA corresponds to a measured vibration velocity that has reached 100% of the measuring range set.

Important: By switching over the Dipswitches, the analog output can be used for setting or reading of the limit values G1 and G2.

The output range 0 to 20mA is suitable for this purpose. For the limit value setting, a current of e.g. 20mA means that the switching threshold is at 100% of the set measuring range, 12mA would then correspond to 60%.

Output Variable	Switch Position		
	S5	S6	S7
Vibration velocity	ON	OFF	OFF
Limiting value G1	OFF	ON	OFF
Limiting value G2	OFF	OFF	ON



14. Adjustment of the limiting values

If the measuring signal exceeds certain limiting values, the ESW[®]-HOL600/Ex Compact_II shall react by switching potential-free relay contacts. These limit values can be set inside the unit by potentiometers. The limit values can be set between 10% and 100% of the selected measuring range.

The limit value G1 will be adjusted with potentiometer P1. Exceeded the value of G1 for example longer as 10s, then K1 is switched. The limit value G2 will be adjusted with potentiometer P2. If limit of G2 will be longer than 5s exceeded, then K2 is switched. Rest the measured value just from time to time over the limit value, so counts the activation delay time after each overstepping of the limit value once more.

When the analog output of the limiting value setting is switched over, the output current related to 20mA will correspond to the setting of the limiting value related to 100% of the measuring range. If, e.g. G1 has to be set to 15mm/s = 30% in the measuring range of 50mm/s, the output range will be first set to 0 to 20mA via S4 and the output variable to limit value G1 via S5=OFF, S6=ON and S7=OFF. After that, a current output of 6mA (= 30% of 20mA) has to be adjusted by potentiometer P1. A current of 8.8mA (= 4mA + 30% of 16mA) should be set in the output range 4 to 20mA. The difference between 4 and 20 is 16 $\Rightarrow$ 30% of 16mA + 4mA = 8.8mA

After setting the limiting values, please pay attention that S5 will be brought to position "ON" and S6, S7 to position "OFF" to activate the function of the analog output as a measuring output.

15. Example to adjust the limit value

Example 1: Analog output 0 to 20mA (mean 0.2mA per %)

Adjust the limit value G1 to 22.5%, and the limit value G2 to 35%:

Measured range 20mm/s	S1	OFF
	S2	ON
	S3	OFF
Analog output 0 to 20mA	S4	ON
Balancing of the limit value G1 to 22.5%	S5	OFF
	S6	ON
	S7	OFF
Set the output current to 4,5mA via P1 (22.5% of 20mA is 4.5mA)		
Balancing of the limit value G2 to 35%	S5	OFF
	S6	OFF
	S7	ON
Set the output current to 7mA via P2 (35% of 20mA is 7mA)		
Measuring variable "vibration velocity"	S5	ON
	S6	OFF
	S7	OFF
Self test off	S8	OFF

Example 2: Analog output 4 to 20mA (mean 0.16mA per %)


Adjust the limit value G1 to 45%, and the limit value G2 to 60%:

Measured range 20mm/s	S1	OFF
	S2	ON
	S3	OFF
Analog output 4 to 20mA	S4	OFF
Balancing of the limit value G1 to 45%	S5	OFF
	S6	ON
	S7	OFF
Set the output current to 11.2mA via P1 (45% of 16mA is 7.2mA + 4mA)		
Balancing of the limit value G2 to 60%	S5	OFF
	S6	OFF
	S7	ON
Set the output current to 13.6mA via P2 (60% of 16mA is 9.6mA + 4mA)		
Measuring variable "vibration velocity"	S5	ON
	S6	OFF
	S7	OFF
Self test off	S8	OFF

16. Self test


A self-test circuit in the unit is integrated to check the ESW[®]-HOL600/Ex Compact_II for checking functionality. The self-test function could be activated by switches inside the unit. The LED LD2 changed light from green to yellow. The LED LD1 and LD3 must turn yellow. After expiration of fixed delay time's K1 and K2 must switch and the LED's LD1 and LD3 must light up red. If the measurement range of 50mm/s has been selected, the analog output provides a current of more than 20mA. In the other measuring ranges' the current must be over 25mA. During the self-test function is the whole electronic incorporated, so that it's possible to obtain a definite information about the function of the unit.

Function	Switch position
Self test on	S8 ON
Self test off	OFF



Upon execution of the self-test function, it's absolutely necessary to return the switch S8 to the position OFF in order to ensure the proper function of the ESW[®]-HOL600/Ex Compact_II. The yellow LED must darken and current has to return to his normal value. In case the yellow LED is lighting and a higher output current is flowing, without of activation of S8, than the electronic recognize one sensor defect and starts alarm, because the electronic is continuously monitoring the sensor.

17. Housing size (in mm), with optional ground on earth terminal



- ① max. useable depth of thread
- ② ground terminal 4mm² (optional)
- ③ measuring axis

Authorization N.B.: BVS 08 ATEX E 089 X

Material: high grade steel V4A

Weight: 2100g


Protection: IP 68

Cable insertion: CAPRI Type ADE 1F-4F, IP68, with Neopren-airtight ring

18. Cable connection draft


Version without external reset

ESW[®]-HOL600/Ex Compact_II



Version include external reset

ESW[®]-HOL600/Ex Compact_II



19. Type registration

The unit with the type registration HOL 6xx/Ex is certified by the ATEX guideline 2014/34 EU for the use in gas-air-mixture under atmospheric conditions or burnable dust.

Labeling / Registration



Wevelinghoven 38
D-41334 Nettetal
www.esw.eu

Typ : ESW[®]-HOL600/Ex Compact_II_***

: ≤ T_{amb} ≤

 : II 2G Ex d IIC T6 Gb

: II 2D Ex tb IIC T80°C Db

: IP 68

Ser.Nr. :

ATEX: BVS 08 ATEX E 089 X  0035
IECEX: IECEX BVS 13.0102 X