

ELECTROSWITCH
UNIT OF ELECTRO SWITCH CORP.
WEYMOUTH MASSACHUSETTS 02188
TEL.:(781)335-5200 FAX:(781)335-4253

SERIES 24 CONTROL SWITCH


2438D



PANEL DRILLING



(3) #10-32 X .75
MOUNTING SCREWS
SUPPLIED





8-32 X .25
BD.HD.TERMINAL SCREWS
SUPPLIED UN-ASSEMBLED.

ACTION: SPRING RETURN TO POS. 2

TITLE: BREAKER CONTROL				
DECK	CONTACTS	POSITION		
		TRIP		CLOSE
		1	2	3
1	18 — 11	X		
	16 — 17			X

HANDLE POSITIONS






NAMEPLATE
CODE 18B-2B23



JUMPERS AND
TERMINALS SUPPLIED
AS SHOWN

CONTACT DECK



DECK 1 BBM

REVISIONS: D ECN 24303 WDS 12/11/97 CJL

MADE BY: S.F.	DATE: 5/7/68		DWG. NO:	REV D
APPR BY: C.I.T.	DATE: 5/7/68		SHEET OF	